

DETAIL ASSOCIATES, INC.
300 GRAND AVENUE
ENGLEWOOD, NJ 07631
(201) 569-6708

CERTIFICATE OF ANALYSIS

CLIENT: Northern Hills Academy
10 Gail Court
Sparta, New Jersey 07871

DATE SAMPLED: 03/19/17
DATE RECEIVED: 03/24/17
DATE ANALYZED: 04/04/17

PROJECT: NJ17-0098

POTABLE WATER ANALYSIS FOR PRESENCE OF LEAD

SAMPLE #	LOCATION	LEAD RESULTS (ppb)
NHA-0319-1L	Room 103 – Sink	*BDL
NHA-0319-2L	Room 105 - Sink	BDL
NHA-0319-3L	Room 102 - Sink	BDL
NHA-0319-4L	Hallway 107A – Water Fountain	BDL
NHA-0319-5L	Room 108 Sink	BDL
NHA-0319-6L	Room 111 - Sink	BDL
NHA-0319-7L	Nurse's Room – 116C Sink	BDL
NHA-0319-8L	Nurse's Room – 116A Sink	BDL
NHA-0319-9L	Room 120 Sink	BDL

*BDL: Below Detection Level of Analytical Method of <3.00 ppb

NEW JERSEY DEP STANDARD LEAD IN DRINKING WATER: 15 ppb (parts per billion)

METHODOLOGY: Lead in Water by Furnace AAS (EPA 200.9)

EMSL Analytical, Inc.

Northern Hills Academy
10 Gail Court, Sparta, New Jersey

Detail Associates, Inc.
Page 1