

**DETAIL ASSOCIATES, INC.**  
300 GRAND AVENUE  
ENGLEWOOD, NJ 07631  
(201) 569-6708

**CERTIFICATE OF ANALYSIS**

**CLIENT:** Northern Hills Academy  
10 Gail Court  
Sparta, New Jersey 07871  
**DATE SAMPLED:** 03/19/17  
**DATE RECEIVED:** 03/24/17  
**DATE ANALYZED:** 04/04/17  
**PROJECT:** NJ17-0098

**POTABLE WATER ANALYSIS FOR PRESENCE OF LEAD**

---

<b>SAMPLE #</b>	<b>LOCATION</b>	<b>LEAD RESULTS (ppb)</b>
NHA-0319-1L	Room 103 – Sink	*BDL
NHA-0319-2L	Room 105 - Sink	BDL
NHA-0319-3L	Room 102 - Sink	BDL
NHA-0319-4L	Hallway 107A – Water Fountain	BDL
NHA-0319-5L	Room 108 Sink	BDL
NHA-0319-6L	Room 111 - Sink	BDL
NHA-0319-7L	Nurse's Room – 116C Sink	BDL
NHA-0319-8L	Nurse's Room – 116A Sink	BDL
NHA-0319-9L	Room 120 Sink	BDL

---

\*BDL: Below Detection Level of Analytical Method of <3.00 ppb  
**NEW JERSEY DEP STANDARD LEAD IN DRINKING WATER:** 15 ppb (parts per billion)  
**METHODOLOGY:** Lead in Water by Furnace AAS (EPA 200.9)

EMSL Analytical, Inc.

Northern Hills Academy  
10 Gail Court, Sparta, New Jersey

Detail Associates, Inc.  
Page 1